

SCS Global Services does hereby certify that an independent assessment has been conducted on behalf of:

AHF, LLC dba AHF Products

3840 Hempland Road, P.O. Box 566, Mountville, PA, United States

For the following product(s):

See Addendum

The product(s) meet(s) all of the necessary qualifications to be certified for the following claim(s):

FloorScore®

Indoor Air Quality Certified to SCS-EC10.3-2014 v4.1

Conforms to the CDPH/EHLB Standard Method v1.2-2017 (California Section 01350), effective April 1, 2017, for the school classroom and private office parameters when modeled as Flooring. Also, conforms to the SCAQMD Rule 1168 - Adhesive and Sealants (October 2017).

Highest Specified Product Application Amount: 330 g/m²

Measured Concentration of Total Volatile Organic Compounds (TVOC): Between 0.5 – 5.0 mg/m³ (in compliance with CDPH/EHLB Standard Method v1.2-2017) Methylene Chloride and Perchloroethylene are not intentionally added to certified products.

Registration # SCS-FS-08496

Valid from: September 1, 2023 to May 31, 2024

SCS Global Services is currently the only certification body approved by the Resilient Floor Covering Institute (RFCI) to provide FloorScore® product certification; certified products are only listed on the SCS Green Products Guide, <http://www.scsglobalservices.com/certified-green-products-guide>.



ANSI National Accreditation Board
ACCREDITED

ISO/IEC 17065
PRODUCT CERTIFICATION
BODY



A handwritten signature in black ink that reads "Stanley Mathuram".

Stanley Mathuram, PE, Executive Vice President
SCS Global Services
2000 Powell Street, Ste. 600, Emeryville, CA 94608 USA

Certification Addendum

AHF, LLC dba AHF Products

Certification: Registration # SCS-FS-08496 | Valid from: September 1, 2023 to May 31, 2024

SCS Global Services is currently the only certification body approved by the Resilient Floor Covering Institute (RFCI) to provide FloorScore® product certification; certified products are only listed on the SCS Green Products Guide, <http://www.scsglobalservices.com/certified-green-products-guide>.

Addendum **FloorScore®**

Conformance: Indoor Air Quality Certified to SCS-EC10.3-2014 v4.1

Conforms to the CDPH/EHLB Standard Method v1.2-2017 (California Section 01350), effective April 1, 2017, for the school classroom and private office parameters when modeled as Flooring. Also, conforms to the SCAQMD Rule 1168 - Adhesive and Sealants (October 2017).

Highest Specified Product Application Amount: 330 g/m²

Measured Concentration of Total Volatile Organic Compounds (TVOC): Between 0.5 – 5.0 mg/m³ (in compliance with CDPH/EHLB Standard Method v1.2-2017) Methylene Chloride and Perchloroethylene are not intentionally added to certified products.

Products: **Flooring Adhesives:**

Armstrong S-202 SDT Adhesive for Static Dissipative Tile, Armstrong S-235 Premium Sheet Flooring Adhesive, Armstrong S-254 Residential Sheet Flooring Adhesive, Armstrong S-289 Releasable & Permanent Flooring Adhesive, Armstrong S-319 Roll Strong, Armstrong S-515 Clear Thin Spread Floor Tile Adhesive, Armstrong S-543 – Commercial Sheet Flooring and LVT Adhesive, Armstrong S-700 Thin-Spread Floor Tile Adhesive, Armstrong S-750 Premium Floor Tile Adhesive, S-392 - SDT Polish, S-480 Polish (Note: These products are coatings)