

SCS Global Services does hereby certify that an independent assessment has been conducted on behalf of:

# Parterre Flooring Systems (a brand of AHF Products)

3840 Hempland Road, Mountville, PA, United States

For the following product(s):

See Addendum

The product(s) meet(s) all of the necessary qualifications to be certified for the following claim(s):

## FloorScore®

Indoor Air Quality Certified to SCS-EC10.3-2014 v4.1

Conforms to the CDPH/EHLB Standard Method v1.2-2017 (California Section 01350), effective April 1, 2017, for the school classroom and private office parameters when modeled as Flooring.

Measured Concentration of Total Volatile Organic Compounds (TVOC): Less than/equal to 0.5 mg/m<sup>3</sup> (in compliance with CDPH/EHLB Standard Method v1.2-2017)

Registration # SCS-FS-06934

Valid from: August 1, 2023 to July 31, 2024

SCS Global Services is currently the only certification body approved by the Resilient Floor Covering Institute (RFCI) to provide FloorScore® product certification; certified products are only listed on the SCS Green Products Guide, <http://www.scsglobalservices.com/certified-green-products-guide>.



ANSI National Accreditation Board

ACCREDITED

ISO/IEC 17065

PRODUCT CERTIFICATION  
BODY



A handwritten signature in black ink that reads "Stanley Mathuram".

Stanley Mathuram, PE, Executive Vice President  
SCS Global Services  
2000 Powell Street, Ste. 600, Emeryville, CA 94608 USA

## **Certification Addendum**

# **Parterre Flooring Systems (a brand of AHF Products)**

Certification: Registration # SCS-FS-06934 | Valid from: August 1, 2023 to July 31, 2024

SCS Global Services is currently the only certification body approved by the Resilient Floor Covering Institute (RFCI) to provide FloorScore® product certification; certified products are only listed on the SCS Green Products Guide, <http://www.scsglobalservices.com/certified-green-products-guide>.

Addendum **FloorScore®**

Conformance: Indoor Air Quality Certified to SCS-EC10.3-2014 v4.1

Conforms to the CDPH/EHLB Standard Method v1.2-2017 (California Section 01350), effective April 1, 2017, for the school classroom and private office parameters when modeled as Flooring.

Measured Concentration of Total Volatile Organic Compounds (TVOC): Less than/equal to 0.5 mg/m<sup>3</sup> (in compliance with CDPH/EHLB Standard Method v1.2-2017)

Products: **Engineered Hardwood:**

Nurtured LTNT6E06W, Nurtured LTNT6E26W, Nurtured LTNT6E36W, Nurtured LTNT6E46W,  
Wooded Habitat LTGR6E04H, Wooded Habitat LTGR6E16S, Wooded Habitat LTGR6E26S,  
Wooded Habitat LTGR6E48W, Wooded Habitat LTGR6E54H, Wooded Habitat LTGR6E64H,  
Wooded Habitat LTGR6E84H, Wooded Habitat LTGR7E41S